IMPARTE
EQUIPAMENTOS DE SEGURANÇA

ANEPC
Registo nº 272

Technical Data Sheet

Designation BOX FOR SIAMESE CONNECTION IN ACCORDANCE WITH NT.13/ANEPC AND PORTARIA 1532

Brand IMPARTE/IMPARTEX **Ref. No.** CXD01

General Description

Fire cabinets are essential structures in any firefighting system, designed to protect, house and extend the service life of the equipment.
They are generally installed in strategic, easily identifiable, easily accessible and unobstructed locations.
They safeguard the equipment needed for an effective and efficient immediate intervention and/or for the fire brigade's intervention.
Cabinets should be checked and maintained periodically to ensure the equipment is operational.
Cabinets come in a wide variety of sizes, with different latches, recessed or wall-mounted, but always made of durable materials resistant to impact and/or vandalism.
Imparte S.A. manufactures all types and sizes of fire service boxes; if your project needs a box made to custom dimensions, contact us by email at geral@imparte.pt

Features

- Protective box for Siamese-type fire inlet, built in accordance with the requirements of Technical Note no. 13 of the National Authority for Emergency and Civil Protection (ANEPC) and Ordinance (Portaria) 1532/2008;
- Box made of 1.25mm electro-galvanised sheet steel;
- 70µm thermosetting electrostatic powder coating, RAL 3001 "Red";
- Solid door with opening no less than 180°;
- Universal stainless steel hinge system;
- Imparte latch made of grey and red polyethylene, sealed with a breakable acrylic seal for emergency opening;
- Fixing holes;

Dimensions

[HxWxD]

- 800x800x500mm_complies with NT.13;
- 700x460x250mm_complies with Portaria 1532/08;
- 700x460x350mm_complies with Portaria 1532/08;
- 800x500x300mm_complies with Portaria 1532/08;

Type of Application

- Recessed or wall mounting;

Standards, certificates, marking and documentation

- In accordance with Technical Note no. 13;
- In accordance with Ordinance (Portaria) 1532/08;

How to order

- Ref. CXD01: dim. 800x800x500mm;
- Ref. CXD01a: dim. 700x460x250mm;
- Ref. CXD01b: dim. 700x460x350mm;
- Ref. CXD01c: dim. 800x500x300mm.



The illustrative images show the product(s) presented; however, they may differ slightly from the final product(s).

www.imparte.pt

HQ| Edifício Imparte, Alto da Barrada,
2785-646 São Domingos de Rana, Portugal

(+351) 214 448 440
(Call to a national landline)

geral@imparte.pt

IMPARTE
EQUIPAMENTOS DE SEGURANÇA

ANEPC
Registo nº 272

Designation BOX FOR SIAMESE CONNECTION IN ACCORDANCE WITH NT.13/ANEPC AND PORTARIA 1532

Brand IMPARTEX / IMPARTE **Ref. No.** CXD01

Additional Products
- Right-hand or left-hand door;
- Made in 304 or 316 stainless steel;
- Painted in another RAL colour, provided it is approved in the project/by site supervision;

Additional Products
- Triangular Yale-type lock;
- Photoluminescent signage in accordance with 92/58/EEC;
- Equipment and mounting accessories not included.

Details

"MINISTRY OF INTERNAL ADMINISTRATION
Ordinance (Portaria) no. 1532/2008 of 29 December
CHAPTER III
Supply and readiness of emergency resources
Article 12 Water availability

(...)

4 — Hydrant valves must be installed recessed in their own box, properly protected and signposted, on the outer walls of the building or on the outer boundary walls of the plot, or under the pavements, next to the kerbs.

5 — On the outer walls of the building or on the outer boundary walls of the plot, hydrant valves must be installed at a height of between 0.6 and 1.0 m above the ground, with one for every 15 m of wall length, or fraction thereof, when the wall exceeds 7.5 m.

(...)"



As an innovative company, IMPARTE S.A. reserves the right to change product specifications, models and standard equipment without prior notice and without incurring any obligation.
For more information visit www.imparte.pt or contact our sales department.

The illustrative images show the product(s) presented; however, they may differ slightly from the final product(s).

www.imparte.pt

HQ| Edifício Imparte, Alto da Barrada,
2785-646 São Domingos de Rana, Portugal

(+351) 214 448 440
(Call to a national landline)

geral@imparte.pt